


Guide for Design of Substation Structures

Prepared by


**Substation Structure Design Guide Subcommittee,
of the Committee on Electrical Transmission
Structures (CETS)**


TWO EXAMPLES IN THE DOCUMENT FOR DETERMINING STRUCTURE LOADS

LINE TERMINATION STRUCTURE



69 KV DISCONNECT SWITCH SUPPORT





3.7.1 Example Load Cases for 69kV Switch Support Structure (Figure 3-6)

Load Case 1

Extreme Wind

90 mph Basic Wind Speed, 3 Sec. Gust, Exp. C

50 Year Mean Recurrence

Load factors from Table 3.17

Load Case 2

Combined Ice + Wind

40 mph Wind + 1.0 in. Ice

50 Year Mean Recurrence

Load factors from Table 3.17

FIGURE 3.6 69kV Switch Support Structure

Load Case 3, Earthquake

$S_s=0.590$

$S_1=0.186$

Soil Profile D

Load factors from Table 3.17

Load Case 4

Short Circuit

15kA Sym

Load factors from Table 3.17

Other Load Cases

Construction /Maintenance Loads

None considered for this example

See Section 3.2.9

Equipment operating Loads

None considered for this example

See Section 3.2.2

Table 3-17 Ultimate Strength Design Cases and Load Factors

LOAD CASES	LOAD FACTORS AND COMBINATIONS
Case 1	$1.1 D + 1.2 W I_{FW} + 0.75 SC + 1.1 T_W$
Case 2	$1.1 D + 1.2 I_W I_{FI}^* + 1.2 W_I I_{FWI}^{**} + 0.75 SC + 1.1 T_W$
Case 3	$1.1 D + 1.0 SC + 1.1 T_W$
Case 4	$1.1 D + 1.25 E(\text{or } E_{FS}) I_{FE} + 0.75 SC + 1.1 T_W$

* The Importance Factor for Ice is applied to the thickness

** The Importance Factor for wind with ice is 1.0, for wind speeds obtained from Figures 3-3a, b, c, d, e, and f per ASCE 7

Note: Replace load factor 1.1 on D with 0.9 for cases in which dead load is counted on to resist other applied loads.

3.7.2 Calculation Of Loading Factors

Extreme Wind Load Case 1

69kV Switch Support Structure:

Assume a rigid structure equipment support (Section 3.2.5.5.1, Para. 2)

$$G_{\text{SRF}} = 0.85$$

$$\begin{aligned} P_v &= 0.00256 \times 0.98 \times (90 \text{ mph})^2 \times 1.00 \times 0.85 \times C_f \times A \\ &= 17.27 \times C_f \times A \\ &= 17.27 \times 1.0 \times A = 17.27 \text{ psf} \times A \text{ wires \& rigid bus} \\ &= 17.27 \times 0.9 \times A = 15.55 \text{ psf} \times A \text{ circular equipment shapes (Post Insulators)} \\ &= 17.27 \times 2.0 \times A = 34.55 \text{ psf} \times A \text{ square structural shapes} \end{aligned}$$

$I_{\text{FW}} = 1.0$: Extreme Wind Importance Factor (50 year mean recurrence)

Load Combination/Factors: $1.1 D + 1.2 W (1.0) + 0.75 SC + 1.1 T_w$ Table 3.17

Combined Ice and Wind, Case 2:

40 mph Wind + 1.00 in. radial Ice

D - Dead Load

T_W - Line Loads

I_W - Ice

Weight of ice on wires, Use 57pcf

Weight of ice on equipment, Use 100% of equipment weight

Weight of ice on structure, Ignore

I_{FI} = 1.0 (50 yr mean recurrence)

I_{FWI} = 1.0 (Per ASCE -7, Figures a, b, c, d, e, and f)

69kV Switch Support Structure:

$$P_V = 0.00256 \times 0.98 \times (40 \text{ mph})^2 \times 1.00 \times 0.85 \times C_f \times A$$

$$= 3.41 \times C_f \times A$$

$$= 3.41 \times 1.0 \times A = 3.41 \text{ psf} \times A \text{ wires \& rigid bus}$$

$$= 3.41 \times 0.9 \times A = 3.07 \text{ psf} \times A \text{ circular equipment shapes}$$

$$= 3.41 \times 2.0 \times A = 6.82 \text{ psf} \times A \text{ square structural shapes}$$

Load Combination/Factors:

$$1.1 D + 1.2 I_W I_{FI} + 1.2 W_I(1.0) + 0.75 SC + 1.1 T_W$$

Table 3.17

Short Circuit Load, Case 3

$F_{SC} = 3.596 \gamma I_{SC}^2 / (10^7 D)$ IEEE 605 (Applicable Equation and design parameters to be recommended by the Electrical Engineer)

$\gamma = 1.00$ phase-phase

$I_{SC} = 15\text{kA} = 15,000\text{A}$

$D = 7$ feet

$$F_{SC} = 3.596 \times 1 \times (15,000\text{A})^2 / (10^7 \times 7 \text{ ft.})$$

$$F_{SC} = 11.6 \text{ plf}$$

Load Combination/Factors: 1.1 D +1.0 SC +1.1 T_w Table 3.17

Earthquake Load, Case 4

$F_a = 1.33$ Table 3-12, Site Class D, $S_S=0.590$ – by interpolation

$F_v = 2.06$ Table 3-13, Site Class D, $S_1=0.186$ – by interpolation

$$S_{DS} = 2/3 F_a S_S \quad \text{Eq. 3-6}$$

$$S_{DS} = 2/3 \times 1.33 \times 0.590$$

$$S_{DS} = 0.523$$

$$S_{D1} = 2/3 F_v S_1 \quad \text{Eq. 3-7}$$

$$S_{D1} = 2/3 \times 2.06 \times 0.186$$

$$S_{D1} = 0.255$$

$$S_a = S_{DS} = 0.523 \quad \text{for } T < S_{D1}/S_{DS} \quad \text{Eq. 3-8}$$

$$S_a = S_{D1}/T = 0.255/T \quad \text{for } T > S_{D1}/S_{DS} \quad \text{Eq. 3-9}$$

For these example assume $S_a = S_{DS}$ controls

$$S_a = S_{DS} = 0.523$$

$$F_E = (S_a/R) W I_{FE} I_{MV} \quad \text{Eq. 3-10}$$

$$F_E = (0.523/2.0) \times W \times 1.25 \times 1.0$$

$$F_E = 0.33 W$$

Where:

$R = 2.0$ for cantilever support (USD)

$I_{FE} = 1.25$ for essential structures & equipment

$I_{MV} = 1.0$ assume significant single mode response

Load Combination/Factors: $1.1 D + 1.25 E + 0.75 SC + 1.1 T_w$

Table 3.17

3.7.4 69kV Switch Support Structure (Figure 3.6), Calculation of Individual Load Components

69kV Disconnect Switch

Weight = 500 lbs./phase

Wind area = Estimate, 10 sq. ft.

Rigid Bus 3" Standard Bus Size (sps) AL (266.8 MCM ACSR damper)

Span = 30 feet

Diameter = 3.5 inches

Weight = 2.991 plf

= (Bus wt. 2.621 plf + Damper wt. 0.370 plf)

Structural members –Square Hollow Structural Section, HSS

Extreme Wind Load, Case 1

D (Dead Load)

$$D_{SW} = 500 \text{ lbs./ Phase}$$

$$D_{BUS} = 2.991 \text{ plf} \times (30 \text{ ft.} / 2) = 45 \text{ lbs./Phase}$$

$$D_{Structure}$$

T_w (Wire Tension): N/A

W (Wind Load)

$$W_{SW} = 15.55 \text{ psf} \times 10 \text{ sq. ft.} = 156 \text{ lbs./Phase}$$

$$W_{BUS} = 17.27 \text{ psf} \times (3.50 \text{ in.} \times 30 \text{ ft.} / 2 / (12 \text{ in./ft.})) \\ = 227 \text{ lbs./Phase}$$

$$W_{Structure} = 34.55 \text{ psf} \times A_{Structure}$$

Extreme Wind Importance Factor: $I_{FW} = 1.0$

Short Circuit Load

$$SC_{BUS} = 11.6 \text{ plf} \times 30 \text{ ft.} / 2 = 167 \text{ lbs.}$$

Load Combination/Factors: $1.1 D + 1.2 W(1.0) + 0.75 SC$

Combined Ice and Wind Load Case 2

D (Dead Load)

$$D_{SW} = 500 \text{ lbs./Phase}$$

$$D_{BUS} = 45 \text{ lbs./Phase}$$

$$D_{Structure}$$

I (Ice Load)

$$I_{BUS} = 57 \text{ pcf} \left(\frac{\pi}{4} (5.50^2 - 3.50^2) \text{ sq. in.} \times 30 \text{ ft.} / 2 / (12 \text{ in./ft.})^2 \right) \\ = 84 \text{ lbs./Phase}$$

$$I_{Structure} = 0$$

I Ice Importance Factor: $I_{FI} = 1.0$

T_w (Wire Tension): $T_w = N/A$

W_{WI} (Wind Load in combination with Ice)

$$W_{SW} = 3.07 \text{ psf} \times 10 \text{ sq. ft.} = 31 \text{ lbs./Phase}$$

$$W_{BUS} = 3.41 \text{ psf} \times (5.50 \text{ in.} \times 30 \text{ ft.} / 2 / (12 \text{ in./ft.})) = 23 \text{ lbs./Phase}$$

$$W_{Structure} = 6.82 \text{ psf} \times A_{Structure} \text{ (Without Ice)}$$

Short Circuit Load

$$SC_{BUS} = 8.1 \text{ plf} \times 30 \text{ ft.} / 2 = 122 \text{ lbs.}$$

Load Combination/Factors: $1.1 D + 1.2 I (1.0) + 1.2 W_{WI} + 0.75 SC$

Earthquake Load Case 4

D (Dead Load)

$$D_{SW} = 500 \text{ lbs./Phase}$$

$$D_{BUS} = 45 \text{ lbs./Phase}$$

$$D_{Structure}$$

$$T_w \text{ (Wire Tension): } T_w = N/A$$

E (Earthquake Load)

$$E_{SW} = 0.33 \times 500 \text{ lbs.} = 165 \text{ lbs./Phase}$$

$$E_{BUS} = 0.33 \times 45 \text{ lbs.} = 15 \text{ lbs./Phase}$$

$$E_{Structure} = 0.33 W \text{ lbs.}$$

Short Circuit Load

$$SC_{BUS} = 8.1 \text{ plf} \times 30 \text{ ft.} / 2 = 122 \text{ lbs.}$$


Load Combination/Factors: 1.1 D + 1.25 E + 0.75 SC

Short Circuit Load Case 3

Load Combination/Factors: $1.1 D + 1.00 SC_{\text{Bus}} + 1.1 T_w$

The designer would apply these load combinations to the structure. Then, using the appropriate analysis method, the member stresses are checked. The deflection load cases would be developed and the deflection limits of Section 4.0 checked.

LINE TERMINATION STRUCTURE



Load Case

NESC Heavy, Grade B (Dead-end Structure)

4 psf Wind + 0.5 in. radial Ice

Load factors from NESC (ANSI C2)

Load Case 1

Extreme Wind

90 mph Basic Wind Speed, 3 Sec. Gust, Exp. C

50 Year Mean Recurrence

Load factors from Table 3.17

Figure 3.5, Dead-End Structure

Extreme Wind Load Case 1

Extreme Wind – 90 mph , Exp C

D - Dead Load

T_W - Line Loads

W – Wind

$$P_V = Q k_Z V^2 I_{FW} G_{RF} C_f A$$

$$Q = 0.00256$$

$$k_Z = 0.98 \quad \text{see Table 3.1 - H=30 ft., Exp C}$$

$$V = 90 \text{ mph} \quad \text{Given}$$

$$I_{FW} = 1.00 \quad \text{see Table 3-3 - 50 Yr.}$$

$$G_{SRF} = 0.96 \quad \text{see Table 3-4a (Wire-support Structure), H<33 ft., Exp C}$$

$$G_{WRF} = 0.92 \quad \text{see Table 3-6b, H<33 ft., Exp C, 100 ft.= L< 250 ft.}$$

$$C_f = 1.0 \quad \text{Table 3-7 (aspect ratio > 40) for wires & rigid bus}$$

$$C_f = 0.9 \quad \text{Table 3-9 for circular equipment shapes}$$

$$C_f = 2.0 \quad \text{Table 3-9 for square structural shapes}$$

Extreme Wind Load Case 1

Dead-End Structure:

$$\begin{aligned} V &= 0.00256 \times 0.98 \times (90 \text{ mph})^2 \times 1.00 \times 0.96 \times C_f \times A \\ &= 19.5 \times C_f \times A \\ &= 19.5 \times 1.0 \times A = 19.5 \text{ psf} \times A \text{ wires \& rigid bus} \\ &= 19.5 \times 0.9 \times A = 17.6 \text{ psf} \times A \text{ circular equipment shapes} \\ &= 19.5 \times 2.0 \times A = 39.0 \text{ psf} \times A \text{ square structural shapes} \end{aligned}$$

$I_{FW} = 1.0$: Extreme Wind Importance Factor (50 year mean recurrence)

Load Combination/Factors: **1.1 D +1.2 W (1.0) + 0.75 SC +1.1 TW** **Table 3.17**

Table 3-4a Structure Response Factor, G_{SRF} , Wire Supporting Structures, $\varepsilon = 0.75$

Height, h (ft)	Exposure B	Exposure C	Exposure D
≤ 33	1.17	0.96	0.85
> 33 to 40	1.15	0.95	0.84
> 40 to 50	1.12	0.94	0.84
> 50 to 60	1.08	0.92	0.83
> 60 to 70	1.06	0.91	0.82
> 70 to 80	1.03	0.89	0.81
> 80 to 90	1.01	0.88	0.81
> 90 to 100	1.00	0.88	0.80

Table 3-4b Structure Response Factor, G_{SRF} , Flexible Non-wire Supporting Structures, $\varepsilon = 1.0$

Height, h (ft)	Exposure B	Exposure C	Exposure D
≤ 15	1.59	1.20	1.02
> 15 to 33	1.48	1.15	0.99
> 33 to 40	1.37	1.11	0.96
> 40 to 50	1.33	1.08	0.95
> 50 to 60	1.28	1.06	0.94
> 60 to 70	1.25	1.05	0.93
> 70 to 80	1.22	1.03	0.92
> 80 to 90	1.19	1.02	0.91
> 90 to 100	1.17	1.00	0.90

$$G_{SRF} = \left(1 + 3.6 (\varepsilon) E_S (B_S)^{0.5} \right) / k_v^2$$

(Eq. 3-3)

Where:

$\varepsilon = 0.75$ Wire Supporting Structures (Dead-end and Line Termination)

$\varepsilon = 1.00$ Flexible Non-Wire Supporting Structures, < 1 Hertz


EXAMPLES

1. BASE PLATE ON CONCRETE
2. BASE PLATE ON LEVELING NUTS
3. BASE PLATE ON LEVELING NUTS IN A DRILLED PIER

7.6.3 Baseplate on Leveling Nuts in a Drilled Pier.

(Distance from top of concrete to bottom of baseplate (h) < 2 times bolt diameter.)

Structure Type: Single Pole Dead-End Structure, 12 Anchor Bolts on a 48 in. Bolt Circle, ASTM A615, Jumbo, Grade 75 Rebar
($F_y = 75$ ksi, $F_{ut} = 100$ ksi)



Applied load with load factors

$$P_u = 34 \text{ kips}$$

$$V_u = 46 \text{ kips}$$

$$M_u = 2380 \text{ ft-kips}$$


Calculate load per bolt

$$P_u = \frac{34 \text{ kips}}{12 \text{ Bolts}} = 2.83 \text{ kips}$$

$$V_u = \frac{46 \text{ kips}}{12 \text{ Bolts}} = 3.83 \text{ kips}$$

Maximum bolt load

$$P_6 = P_{12}$$



$$P_{12} = \frac{M_u d_{12}}{\Sigma d_{1to12}^2} = \frac{2380 \text{ ft} - \text{kips} (12'' / \text{ft})(24'')}{4(12'')^2 + 4(20.8'')^2 + 2(24'')^2} = 198 \text{ kips}$$

$$P_{\text{TOTAL}} = 2.83 \text{ kips} + 198 \text{ kips} = 201 \text{ kips}$$

$$A_a = \frac{P_u}{f_{dt}} = \frac{P_u}{\phi f_y} = \frac{201 \text{ kips}}{0.9(75 \text{ ksi})} = 2.98 \text{ in}^2 \langle \text{CONTROLS} \rangle$$

or

$$A_a = \frac{P_u}{0.8f_{ut}} = \frac{201 \text{ kips}}{0.8(100 \text{ ksi})} = 2.51 \text{ in}^2$$

$$A_v = \frac{V_u}{\phi f_y} = \frac{3.83 \text{ kips}}{0.85(75 \text{ ksi})} = 0.06 \text{ in}^2$$

$$A_s = A_a + A_v = 2.98 \text{ in}^2 + 0.06 \text{ in}^2 = 3.04 \text{ in}^2$$

**REQUIRED
AREA**

A_s required 3.04 in²

Use No. 18 Jumbo (#18J), Grade 75 ($A_s = 3.25$ in²)

Development of Deformed Bars in Tension, ACI-318 12.2.2

$$l_d = d_b \frac{f_y \Psi_t \Psi_e \lambda}{20 \sqrt{f_c'}} = 2.25 \frac{75,000(1)(1)(1)}{20 \sqrt{4000} \text{ psi}} = 133.4 \text{ in}$$

$l_d = 133.4$ in. Use 134 in.

Reduction for (A_s required) / (A_s provided) from ACI 318 12.2.5

A_s required = 3.25 in² (Use actual #18J bar A_s of thread area)

A_s provided = 4.00 in² (area of #18J bar)

$$l_d = 134 \text{ in} \left(\frac{3.25}{4.00} \right) = 108'' = 9'-1'' \text{ Embedment}$$

THE END

