

SECTION 5 – EXAMPLES

5.0 LATTICE SUSPENSION TOWER LOADS

This example shows calculations for wire and structure loads. The loads are based on the tower shown in Figure 5.0-1 and the design and wire data listed below.




Figure 5.0-1 Suspension Tower

Design Data:

The transmission line is located in Utah.

Relative Reliability Factor	= 1
Ruling Span	= 1250 ft
Wind Span	= 1500 ft
Weight Span	= 1800 ft
Line Angle	= 5 degrees
Length of Insulator Assembly	= 6 ft
Weight of Insulator Assembly	= 200 lbs
Weight of Ground Wire Assembly	= 50 lbs

Wire Data:


Loading Case	Temp (°F)	Ice (in)	Wind (psf)	954 kcmil 45/7 ACSR RAIL Conductor ($d = 1.165$ in, $w = 1.075$ lbs/ft)		7#8 Aluminum Clad Steel Ground Wire ($d = 0.385$ in, $w = 0.262$ lbs/ft)	
				Initial Sag (ft)	Initial Tension (lbs)	Initial Sag (ft)	Initial Tension (lbs)
Wind	60	0	16.3	43.7	8598	39.0	2939
Wind @ 30	60	0	12.2	42.3	7428	37.2	2481
Wind and Ice	15	0.273	1.81	39.2	7921	35.8	2767
NESC	15	0.25	4	40.4	8800	39.5	3700
C&M	15	0	3	36.6	5961	31.2	1751
FC	30	0	0	37.5	5615	31.6	1623
No Wind	60	0	0	39.8	5302	33.2	1546

Wind pressures for the **Wind** and **Wind @ 30** loading cases are a function of the span length. They are generated using the wind span instead of the ruling span. However, for calculations of sags and tensions, the use of the ruling span is more appropriate.

Wind (Extreme Wind, Section 2.1)

Wind is normal to the ahead span, back span, and to the structure. The structure is located on the perpendicular bisector of the line angle.

From the wind map (Figure 2.1.3-1), V_{50} equals 90 mph. The exposure category is C.



Wind on Wires:

$$\text{Average wire height } (z_h) = [3(74)+2(89)]/5 = 80 \text{ ft} \quad (\text{Sect. 2.1.4.3})$$

$$K_z = 2.01(z_h/z_g)^{2/\alpha} = 2.01(80/900)^{2/9.5} = 1.21 \quad (\text{Eq. 2.1.4-1})$$

$$E = 4.9(\kappa)^{1/2}(33/z_h)^{1/\alpha_{FM}} = 4.9(0.005)^{1/2}(33/80)^{1/7} = 0.305 \quad (\text{Eq. 2.1.5-3})$$

$$B_w = 1/(1+0.8L/L_s) = 1/(1+0.8(1500)/220) = 0.155 \quad (\text{Eq. 2.1.5-4})$$

$$G_w = [1+2.7E(B_w)^{1/2}]/k_v^2 = [1+2.7(0.305)(0.155)^{1/2}]/1.43^2 = 0.648 \quad (\text{Eq. 2.1.5-1})$$

$$\begin{aligned} \text{Wind pressure} &= \gamma_w Q K_z (V_{50})^2 G_w C_f \\ &= 1.0(0.00256)(1.21)(90)^2(0.648)1.0 = 16.3 \text{ psf} \end{aligned} \quad (\text{Eq. 2.1-1a})$$

Ground Wire Loads:

$$V = 0.262(1800)+50 = 522 \text{ lbs} = 0.5 \text{ kips}$$

$$T = 16.3(0.385/12)(1500)+2939 \sin(5/2)(2) = 1041 \text{ lbs} = 1.0 \text{ kips}$$

Conductor Loads:

$$V = 1.075(1800)+200 = 2135 \text{ lbs} = 2.1 \text{ kips}$$

$$T = 16.3(1.165/12)(1500)+8598 \sin(5/2)(2) = 3124 \text{ lbs} = 3.1 \text{ kips}$$

Wind on Structure:

$$\text{Two thirds of the structure height } (z_h) = 2(89)/3 = 59.3 \text{ ft} \quad (\text{Sect. 2.1.4.3})$$

$$K_z = 2.01(z_h/z_g)^{2/\alpha} = 2.01(59.3/900)^{2/9.5} = 1.13 \quad (\text{Eq. 2.1.4-1})$$

$$E = 4.9(\kappa)^{1/2}(33/z_h)^{1/\alpha_{FM}} = 4.9(0.005)^{1/2}(33/59.3)^{1/7} = 0.319 \quad (\text{Eq. 2.1.5-3})$$

$$B_t = 1/(1+0.56z_h/L_s) = 1/(1+0.56(59.3)/220) = 0.869 \quad (\text{Eq. 2.1.5-5})$$

$$G_t = [1+2.7E(B_t)^{1/2}]/k_v^2 = [1+2.7(0.319)(0.869)^{1/2}]/1.43^2 = 0.882 \quad (\text{Eq. 2.1.5-2})$$

$$\begin{aligned} \text{Wind pressure} &= \gamma_w Q K_z (V_{50})^2 G_t \\ &= 1.0(0.00256)(1.13)(90)^2 0.882 = 20.7 \text{ psf} \end{aligned} \quad (\text{Eq. 2.1-1a})$$

Figure 5.0-1 shows tower areas and solidity ratios.

Transverse Wind Loads:

$$\text{For } \Phi_1 = 0.69, C_{f1} = 1.8, \text{ and } A_1 = 34 \text{ ft}^2$$

$$\text{For } \Phi_2 = 0.17, C_{f2} = 4.1-5.2\Phi = 4.1-5.2(0.17) = 3.22, \text{ and } A_2 = 33 \text{ ft}^2$$

$$\text{For } \Phi_3 = 0.15, C_{f3} = 4.1-5.2\Phi = 4.1-5.2(0.15) = 3.32, \text{ and } A_3 = 62 \text{ ft}^2$$

where force coefficient equations are from Table 2.1.6-1.

$$W_1 = 20.7(1.8)(34) = 1267 \text{ lbs} = 1.3 \text{ kips}$$

$$W_2 = 20.7(3.22)(33) = 2200 \text{ lbs} = 2.2 \text{ kips}$$

$$W_3 = 20.7(3.32)(62) = 4261 \text{ lbs} = 4.3 \text{ kips}$$

Wind @30 (Extreme Wind @ 30° Yaw Angle, Section 2.1)

Wind is at a 30 degree yaw angle.

Wind on Wires:

From the **Wind** load case, the wind pressure normal to the wires equals 16.3 psf.

$$\text{Wind pressure} = 16.3 \cos^2\Psi = 16.3 \cos^2(30) = 12.2 \text{ psf} \quad (\text{Eq. 2.1.6-4})$$

Ground Wire Loads:

$$V = 0.262(1800)+50 = 522 \text{ lbs} = 0.5 \text{ kips}$$

$$T = 12.2(0.385/12)(1500)+2481 \sin(5/2)(2) = 804 \text{ lbs} = 0.8 \text{ kips}$$

Conductor Loads:

$$V = 1.075(1800)+200 = 2135 \text{ lbs} = 2.1 \text{ kips}$$

$$T = 12.2(1.165/12)(1500)+7428 \sin(5/2)(2) = 2425 \text{ lbs} = 2.4 \text{ kips}$$

Wind on Structure:

From the **Wind** load case, the structure wind pressure equals 20.7 psf.
Use the first alternative in Section 2.1.6.2.3.

Transverse Wind Loads:

$$\text{Wind pressure} = 20.7 \cos \Psi = 20.7 \cos(30) = 17.9 \text{ psf} \quad (\text{Eq. 2.1.6-5a})$$

Force coefficients and areas are provided in the **Wind** loading case.

$$W_1 = 17.9(1.8)(34) = 1096 \text{ lbs} = 1.1 \text{ kips}$$

$$W_2 = 17.9(3.22)(33) = 1902 \text{ lbs} = 1.9 \text{ kips}$$

$$W_3 = 17.9(3.32)(62) = 3684 \text{ lbs} = 3.7 \text{ kips}$$

Longitudinal Wind Loads:

$$\text{Wind pressure} = 20.7 \sin \Psi = 20.7 \sin(30) = 10.4 \text{ psf} \quad (\text{Eq. 2.1.6-5b})$$

$$\text{For } \Phi_4 = 0.26, C_{f4} = 4.1-5.2\Phi = 4.1-5.2(0.26) = 2.75, \text{ and } A_4 = 43 \text{ ft}^2$$

$$\text{For } \Phi_5 = 0.24, C_{f5} = 4.1-5.2\Phi = 4.1-5.2(0.24) = 2.85, \text{ and } A_5 = 37 \text{ ft}^2$$

$$\text{For } \Phi_6 = 0.16, C_{f6} = 4.1-5.2\Phi = 4.1-5.2(0.16) = 3.27, \text{ and } A_6 = 67 \text{ ft}^2$$

where force coefficient equations are from Table 2.1.6-1.

$$W_4 = 10.4(2.75)(43) = 1230 \text{ lbs} = 1.2 \text{ kips}$$

$$W_5 = 10.4(2.85)(37) = 1097 \text{ lbs} = 1.1 \text{ kips}$$

$$W_6 = 10.4(3.27)(67) = 2279 \text{ lbs} = 2.3 \text{ kips}$$


where force coefficient equations are from Table 2.1.6-1.

Wind and Ice (Extreme Radial Glaze Ice with Wind, Section 2.3)

Wind on Wires:

From the **Wind** load case, K_z equals 1.21 and G_w equals 0.648.

From the wind and ice map (Figure 2.3-1a), I_{50} equals 0.25 in and V_1 equals 30 mph.



Notes:

1. Ice thicknesses on structures in exposed locations at elevations higher than the surrounding terrain and in valleys and gorges may exceed the mapped values.
2. In the mountain west, indicated by the shading, ice thicknesses may exceed the mapped values in the foothills and passes. However, at elevations above 5,000 ft, freezing rain is unlikely.
3. In the Appalachian Mountains, indicated by the shading, ice thicknesses may vary significantly over short distances.

$$\begin{aligned} \text{Wind pressure} &= Q K_z (V_1)^2 G_w C_f && \text{(Eq. 2.1-1a)} \\ &= 0.00256(1.21)(30)^2(0.648)1.0 = 1.81 \text{ psf} \end{aligned}$$

$$\begin{aligned} I_z &= I(z_r/33)^{0.10} && \text{(Eq. 2.3-1)} \\ &= 0.25(80/33)^{0.10} = 0.273 \text{ in} \end{aligned}$$

Ground Wire Loads:

$$\begin{aligned} W_i &= 1.24(d + I_z)I_z && \text{(Eq. 2.3-3)} \\ &= 1.24(0.385 + 0.273)0.273 = 0.223 \text{ lbs/ft} \end{aligned}$$

$$d_i = 2(0.273) + 0.385 = 0.931 \text{ in}$$

$$V = 1800(0.262 + 0.223) + 50 = 923 \text{ lbs} = 0.9 \text{ kips}$$

$$T = 1.81(0.931/12)(1500) + 2767 \sin(5/2)(2) = 452 \text{ lbs} = 0.5 \text{ kips}$$

Conductor Loads:

$$\begin{aligned} W_i &= 1.24(d + I_z)I_z && \text{(Eq. 2.3-3)} \\ &= 1.24(1.165 + 0.273)0.273 = 0.487 \text{ lbs/ft} \end{aligned}$$

$$d_i = 2(0.273) + 1.165 = 1.711 \text{ in}$$

$$V = 1800(1.075+0.487)+200 = 3012 \text{ lbs} = 3.0 \text{ kips}$$

$$T = 1.81(1.711/12)(1500)+7921 \sin(5/2)(2) = 1078 \text{ lbs} = 1.1 \text{ kips}$$

Wind on Structure:

From the **Wind** loading case, K_z equals 1.13 and G_t equals 0.882.

$$\text{Wind pressure} = Q K_z (V_i)^2 G_t \quad (\text{Eq. 2.1-1a})$$

$$= 0.00256(1.13)(30)^2 0.882 = 2.30 \text{ psf}$$

Transverse Wind Loads:

Force coefficients and areas are provided in the **Wind** loading case.

$$W_1 = 2.3(1.8)(34) = 141 \text{ lbs} = 0.1 \text{ kips}$$

$$W_2 = 2.3(3.22)(33) = 244 \text{ lbs} = 0.2 \text{ kips}$$

$$W_3 = 2.3(3.32)(62) = 473 \text{ lbs} = 0.5 \text{ kips}$$

HIW (High Intensity Wind, Section 2.2)

Eighty-six percent of the tornadoes are F2 or smaller (Table 2.2.1-2). This rating corresponds to a wind speed of 157 mph. Wind is applied on the structure and wire loads are assumed to be zero.

F-scale (gust wind speed range)	Number of Tornadoes	Percentage	Cumulative percentage
F0 (40-72 mph)	5718	22.9	22.9
F1 (73-112 mph)	8645	34.7	57.6
F2 (113-157 mph)	7102	28.5	86.1
F3 (158-206 mph)	2665	10.7	96.8
F4 (207-260 mph)	673	2.7	99.5
F5 (261-318 mph)	127	0.5	100.0
Total	24,930	100.0	

Three loading cases are calculated, 0, 90, and 45 degree yaw angles.

Wind on Structure:

$$K_z = G_t = 1.0$$

$$\text{Wind pressure} = Q K_z (V)^2 G_t = 0.00256(1.0)(157)^2 (1.0) = 63.1 \text{ psf}$$

0 degree yaw angle:

Transverse Wind Loads:

Force coefficients and areas are provided in the **Wind** loading case.

$$W_1 = 63.1(1.8)(34) = 3862 \text{ lbs} = 3.9 \text{ kips}$$

$$W_2 = 63.1(3.22)(33) = 6705 \text{ lbs} = 6.7 \text{ kips}$$

$$W_3 = 63.1(3.32)(62) = 12989 \text{ lbs} = 13.0 \text{ kips}$$

90 degree yaw angle:

Longitudinal Wind Loads:

Force coefficients and areas are provided in the **Wind@30** loading case.

$$W_4 = 63.1(2.75)(43) = 7461 \text{ lbs} = 7.5 \text{ kips}$$

$$W_5 = 63.1(2.85)(37) = 6654 \text{ lbs} = 6.7 \text{ kips}$$

$$W_6 = 63.1(3.27)(67) = 13825 \text{ lbs} = 13.8 \text{ kips}$$

45 degree yaw angle:

Transverse Wind Loads:

$$\text{Wind pressure} = 63.1 \cos\Psi = 63.1 \cos(45) = 44.6 \text{ psf} \quad (\text{Eq. 2.1.6-5a})$$

Force coefficients and areas are provided in the **Wind** loading case.

$$W_1 = 44.6(1.8)(34) = 2730 \text{ lbs} = 2.7 \text{ kips}$$

$$W_2 = 44.6(3.22)(33) = 4739 \text{ lbs} = 4.7 \text{ kips}$$

$$W_3 = 44.6(3.32)(62) = 9180 \text{ lbs} = 9.2 \text{ kips}$$

Longitudinal Wind Loads:

$$\text{Wind pressure} = 63.1 \sin\Psi = 63.1 \sin(30) = 44.6 \text{ psf} \quad (\text{Eq. 2.1.6-5b})$$

Force coefficients and areas are provided in the **Wind@30** loading case.

$$W_4 = 44.6(2.75)(43) = 5274 \text{ lbs} = 5.3 \text{ kips}$$

$$W_5 = 44.6(2.85)(37) = 4703 \text{ lbs} = 4.7 \text{ kips}$$

$$W_6 = 44.6(3.27)(67) = 9771 \text{ lbs} = 9.8 \text{ kips}$$

NESC

From the NESC General Loading Map of the United States (Fig. 250-1), Utah is in the medium loading district. Rule 250C (Extreme Wind) is not included in this example.

Wind on Wires:

$$\text{Wind pressure} = 4 \text{ psf}$$

Ground Wire Loads:

$$W_i = 1.24(d + l_z)l_z \quad (\text{Eq. 2.3-3})$$
$$= 1.24(0.385 + 0.25)0.25 = 0.197 \text{ lbs/ft}$$

$$d_i = 2(0.25) + 0.385 = 0.885 \text{ in}$$

$$V = 1800(0.262 + 0.197)(1.5) + 50(1.5) = 1314 \text{ lbs} = 1.3 \text{ kips}$$

$$T = 4(0.885/12)(1500)(2.5) + 3700 \sin(5/2)(2)(1.65) = 1638 \text{ lbs} = 1.6 \text{ kips}$$

Conductor Loads:

$$W_i = 1.24(d + l_z)l_z \quad (\text{Eq. 2.3-3})$$
$$= 1.24(1.165 + 0.25)0.25 = 0.439 \text{ lbs/ft}$$

$$d_i = 2(0.25) + 1.165 = 1.665 \text{ in}$$

$$V = 1800(1.075 + 0.439)(1.5) + 200(1.5) = 4388 \text{ lbs} = 4.4 \text{ kips}$$

$$T = 4(1.665/12)(1500)(2.5) + 8800 \sin(5/2)(2)(1.65) = 3348 \text{ lbs} = 3.3 \text{ kips}$$

Wind on Structure:

Transverse Wind Loads:

$$\text{Wind pressure} = 4(2.5) = 10 \text{ psf}$$

Areas are provided in the **Wind** loading case.

The NESC force coefficient is 3.2.

$$W_1 = 10(3.2)(34) = 1088 \text{ lbs} = 1.1 \text{ kips}$$

$$W_2 = 10(3.2)(33) = 1056 \text{ lbs} = 1.1 \text{ kips}$$

$$W_3 = 10(3.2)(62) = 1984 \text{ lbs} = 2.0 \text{ kips}$$

C&M (Construction and Maintenance, Section 3.1)

Wind on Wires:

Wind pressure = 3 psf

Ground Wire Loads:

Alt. A ...Snubbing Wires - the pulling slope is 3 horizontal to 1 vertical.

Alt. B: Two times the weight span.

$$V = 1.5(1751)(1/3)+0.262(1800)(1.5)/2+50(1.5)= 1304 \text{ lbs} = 1.3 \text{ kips (Alt. A controls)}$$

$$V = 0.262(1800)(2)+50(2) = 1043 \text{ lbs} = 1.1 \text{ kips (Alt. B)}$$

$$T = 3(0.385/12)(1500)1.5+1751 \sin(5/2)(2)1.5 = 446 \text{ lbs} = 0.5 \text{ kips}$$

Conductor Loads:

$$V = 1.5(5961)(1/3)+1.075(1800)(1.5)/2+200(1.5)= 4732 \text{ lbs} = 4.7 \text{ kips (Alt. A controls)}$$

$$V = 1.075(1800)2+200(2) = 4270 \text{ lbs} = 4.3 \text{ kips (Alt. B)}$$

$$T = 3(1.165/12)(1500)1.5+5961 \sin(5/2)(2)1.5 = 1435 \text{ lbs} = 1.4 \text{ kips}$$

Wind on Structure:

Transverse Wind Loads:

Wind pressure = $3(1.5) = 4.5$ psf

Force coefficients and areas are provided in the **Wind** loading case.

$$W_1 = 4.5(1.8)(34) = 275 \text{ lbs} = 0.3 \text{ kips}$$

$$W_2 = 4.5(3.22)(33) = 478 \text{ lbs} = 0.5 \text{ kips}$$

$$W_3 = 4.5(3.32)(62) = 926 \text{ lbs} = 0.9 \text{ kips}$$

FC (Failure Containment, Section 3.3.2)

This loading case is based on the residual static load of a broken conductor or ground wire (0 psf wind and 0 inches of radial ice at 30°F).

Ground Wire Loads:

The RSL load factor for a broken ground wire is 1.0.

Broken Wire:

$$V = 0.262(1800)/2+50 = 286 \text{ lbs} = 0.3 \text{ kips}$$

$$T = 1623 \sin(5/2)(1.0) = 71 \text{ lbs} = 0.1 \text{ kips}$$

$$L = 1623 \cos(5/2)(1.0) = 1621 \text{ lbs} = 1.6 \text{ kips}$$

Intact Wires:

$$V = 0.262(1,800)+50 = 522 \text{ lbs} = 0.5 \text{ kips}$$

$$T = 1623 \sin(5/2)(2) = 142 \text{ lbs} = 0.1 \text{ kips}$$


$$L = = 0.0 \text{ kips}$$

Conductor Loads:

$$\text{Ratio of the span to insulator length} = 1250/6 = 208$$

$$\text{Ratio of the span to sag} = 1250/31.6 = 40$$

From Figure 3.3-2, the RSL load factor is 0.7.



Broken Wire:

$$\begin{aligned}
 V &= 1.075(1800)/2+200 &= 1168 \text{ lbs} &= 1.2 \text{ kips} \\
 T &= 5615 \sin(5/2)(0.7) &= 171 \text{ lbs} &= 0.2 \text{ kips} \\
 L &= 5615 \cos(5/2)(0.7) &= 3927 \text{ lbs} &= 3.9 \text{ kips}
 \end{aligned}$$

Intact Wires:

$$\begin{aligned}
 V &= 1.075(1800)+200 &= 2135 \text{ lbs} &= 2.2 \text{ kips} \\
 T &= 5615 \sin(5/2)(2) &= 490 \text{ lbs} &= 0.5 \text{ kips} \\
 L &= &= &= 0.0 \text{ kips}
 \end{aligned}$$

Load Summary

All loads are in kips.

Loading Case	Ground Wire			Conductor			Transverse Wind on Structure			Longitudinal Wind on Structure		
	V	T	L	V	T	L	W ₁	W ₂	W ₃	W ₄	W ₅	W ₆
Wind	0.5	1.0		2.1	3.1		1.3	2.2	4.3			
Wind @ 30	0.5	0.8		2.1	2.4		1.1	1.9	3.7	1.2	1.1	2.3
Wind and Ice	0.9	0.5		3.0	1.1		0.1	0.2	0.5			
HIW @ 0 deg							3.9	6.7	13.0			
HIW @ 90 deg										7.5	6.7	13.8
HIW @ 45 deg							2.7	4.7	9.2	5.3	4.7	9.8
NESC	1.3	1.6		4.4	3.3		1.1	1.1	2.0			
C&M	1.3	0.5		4.7	1.4		0.3	0.5	0.9			
FC (Broken Wire)	0.3	0.1	1.6	1.2	0.2	3.9						
FC (Intact)	0.5	0.1		2.2	0.5							

5.1 WEIGHT SPAN CHANGE WITH BLOWOUT ON INCLINED SPANS

This example compares weight spans with and without wind for the center tower shown in Figure 5.1-1. The equations are shown in Section 4.5.1.1. Wire data is from Section 5.0.




Figure 5.1-1. Weight Span for Center Tower with Inclined Spans

Ground Wire:

No Wind:

$$C_v = H/w_v = 1546/0.262 = 5901 \text{ ft} \quad (\text{Eq. 4-7})$$

$$X_1 = L/2 - C_v \sinh^{-1}[(B/2)/C_v \sinh(L/2C_v)] \quad (\text{Eq. 4-5})$$

$$= 1250/2 - 5901 \sinh^{-1}[(50/2)/5901 \sinh(1250/2(5901))] = 390 \text{ ft}$$

$$\text{Weight span} = 2(1250 - 390) = 1720 \text{ ft}$$

16.3 psf Wind:

$$C_v = 2939/0.262 = 11218 \text{ ft} \quad (\text{Eq. 4-7})$$

$$X_1 = 1250/2 - 11218 \sinh^{-1}[(50/2)/11218 \sinh(1250/2(11218))] = 177 \text{ ft} \quad (\text{Eq. 4-5})$$

$$\text{Weight span} = 2(1250 - 177) = 2146 \text{ ft} \quad \mathbf{25\% \text{ increase}}$$

Conductor:

No Wind:

$$C_v = 5302/1.075 = 4932 \text{ ft}$$

$$X_1 = 1250/2 - 4932 \sinh^{-1}[(50/2)/4932 \sinh(1250/2(4932))] = 428 \text{ ft}$$

$$\text{Weight span} = 2(1250 - 428) = 1644 \text{ ft}$$

16.3 psf Wind:

$$C_v = 8598/1.075 = 7998 \text{ ft}$$

$$X_1 = 1250/2 - 7998 \sinh^{-1}[(50/2)/7998 \sinh(1250/2(7998))] = 306 \text{ ft}$$

$$\text{Weight span} = 2(1250 - 306) = 1888 \text{ ft} \quad \mathbf{15\% \text{ increase}}$$

5.2 TRADITIONAL CATENARY CONSTANT

This example compares weight spans to those in Section 5.1 using the traditional catenary constant. The traditional catenary constant is based on the resultant unit weight (w_r). The catenary constant in Section 5.1 is based on the vertical unit weight (w_v).

Figure 5.1-1 shows the upper and lower towers and spans.

Ground Wire:

16.3 psf Wind:

$$\begin{aligned} w_v &= &= 0.262 \text{ lbs/ft} \\ w_t &= 16.3(0.385/12) &= 0.523 \text{ lbs/ft} \\ w_r &= (0.262^2 + 0.523^2)^{1/2} &= 0.585 \text{ lbs/ft} \end{aligned}$$

$$C_r = H/w_r = 2939/0.585 = 5025 \text{ ft} \quad (\text{Eq. 4-6})$$

$$\begin{aligned} X_1 &= L/2 - C_r \sinh^{-1}[(B/2)/C_r \sinh(L/2C_r)] & (\text{Eq. 4-5}) \\ &= 1250/2 - 5025 \sinh^{-1}[(50/2)/5025 \sinh(1250/2(5025))] = 425 \text{ ft} \end{aligned}$$

$$\text{Weight span} = 2(1250 - 425) = 1650 \text{ ft}$$

Conductor:

16.3 psf Wind:

$$\begin{aligned} w_v &= &= 1.075 \text{ lbs/ft} \\ w_t &= 16.3(1.165/12) &= 1.582 \text{ lbs/ft} \\ w_r &= (1.075^2 + 1.582^2)^{1/2} &= 1.913 \text{ lbs/ft} \end{aligned}$$

$$C_r = 8598/1.913 = 4494 \text{ ft} \quad (\text{Eq. 4-6})$$

$$X_1 = 1250/2 - 4494 \sinh^{-1}[(50/2)/4494 \sinh(1250/2(4494))] = 446 \text{ ft} \quad (\text{Eq. 4-5})$$

$$\text{Weight span} = 2(1250 - 446) = 1608 \text{ ft}$$

Weight Span Summary:

Wire	C	Upper Tower		Lower Tower	
		Weight Span (ft)	Difference	Weight Span (ft)	Difference
Ground Wire	Traditional	1650	23%	425	140%
	Section 5.1	2146		177	
Conductor	Traditional	1608	15%	446	45%
	Section 5.1	1888		306	

The traditional catenary constant under estimates the vertical load on the upper tower and over estimates the vertical load on the lower tower.